

The following is an excerpt of lead test results from the Department of Energy & Environment website at <http://doee.dc.gov/publication/water-sampling-results-district-schools>.

This data reflects lead test results for Capitol Hill Montessori at Logan for testing done in August 2015 and March 2016

Note: Here is the information setup in the matrix below to correlate the results from 2015 and 2106.

August 20, 2015	Pass	Fail	March 28, 2016	Pass	Fail
First Floor Hallway Adjacent to Rm 109	<1		1st floor hallway adjacent to Classroom 109	< 1	
First Floor Hallway Adjacent to Rm 109	<1		1st floor hallway adjacent to Classroom 109	< 1	
Second Floor Hallway Adjacent to Rm 212	<1		Not functioning at time of test		
Second Floor Hallway Adjacent to Rm 212	<1		Not functioning at time of test		
Second Floor Hallway Adjacent to Rm 202 (high)	<1		Not functioning at time of test		
Second Floor Hallway Adjacent to Rm 202 (low)	1.5		Not functioning at time of test		
Second Floor Hallway Adjacent to Rm 202 (low)	<1		Not functioning at time of test		
Second Floor Hallway Adjacent to Rm 202 (low)	2.2		Not functioning at time of test		
First Floor Hallway Adjacent to Rm 101	<1		1st floor hallway adjacent to Classroom 101	< 1	
First Floor Hallway Adjacent to Rm 101	<1		1st floor hallway adjacent to Classroom 101	< 1	
First Floor Hallway Between restrooms (left)		15	1st floor hallway in Annex Building adjacent to Women's room (left, high)	< 1	
First Floor Hallway Between restrooms (left)		15	1st floor hallway in Annex Building adjacent to Women's room (left, high)	< 1	
First Floor Hallway Between restrooms (middle)		16	1st floor hallway in Annex Building adjacent to Women's room (middle, low)	< 1	
First Floor Hallway Between restrooms (middle)	13		1st floor hallway in Annex Building adjacent to Women's room (middle, low)	< 1	
First Floor Hallway Between restrooms (right)		320	1st floor hallway in Annex Building adjacent to Women's room (right, high)	< 1	
First Floor Hallway Between restrooms (right)	9.7		1st floor hallway in Annex Building adjacent to Women's room (right, high)	< 1	
First Floor inside cafeteria	<1		Basement floor inside Cafeteria	< 1	
First Floor inside cafeteria	4		Basement floor inside Cafeteria	< 1	